



America


CERTIFICATE

No. U8 15 10 80346 011

Holder of Certificate: **Fortress Interlocks Ltd**

2 Inverclyde Drive
Wolverhampton
West Midlands WV4 6FB
UNITED KINGDOM

Certification Mark:



Product:

**Safety components
Control units**

The product was voluntarily tested according to the relevant safety requirements noted above. It can be marked with the certification mark above. The mark must not be altered in anyway. This product certification system operated by TÜV SÜD America Inc. most closely resembles system 3 as defined in ISO/IEC Guide 67. Certification is based on the TÜV SÜD "Testing and Certification Regulations". TÜV SÜD America Inc. is an OSHA recognized NRTL and a Standards Council of Canada accredited certification body.

Test report no.:

028-713068839-000



Date, 2015-11-16

Page 1 of 8



America

CERTIFICATE**No. U8 15 10 80346 011****Model(s):****tGard****Additional Information please see attachment****Parameters:**

Rated voltage:
 Rated current:
 Rated frequency:
 Degree of protection against liquids

Switches
 24V AC/DC
 0,5A
 50/60Hz
 IP65 –
 (Type 1 Enclosure)

Rated voltage:
 Rated current:
 Rated frequency:
 Degree of protection against liquids

Pushbuttons
 24V DC
 0,1A

 IP65 –
 (Type 1 Enclosure)

Rated voltage:
 Rated current:
 Rated frequency:
 Degree of protection against liquids

Solenoid
 24V DC
 0,35A

 IP65 –
 (Type 1 Enclosure)

Tested according to:

UL 508/R:2013-10
 CAN/CSA-C22.2 No. 14-13:2013-03

Production Facility(ies):

80346