



America

CERTIFICATE

No. U8 18 01 80346 018

Holder of Certificate: Fortress Interlocks Ltd

2 Inverclyde Drive
Wolverhampton
West Midlands WV4 6FB
UNITED KINGDOM

Certification Mark:**Product:**

**Industrial Control Systems and
Components
(Switches of S40 Series)**

The product was voluntarily tested according to the relevant safety requirements noted above. It can be marked with the certification mark above. The mark must not be altered in any way. This product certification system operated by TÜV SÜD America Inc. most closely resembles system 3 as defined in ISO/IEC 17067. Certification is based on the TÜV SÜD "Testing and Certification Regulations". TÜV SÜD America Inc. is an OSHA recognized NRTL and a Standards Council of Canada accredited certification body.

Test report no.:

028-713117652-000

Date, 2018-01-10

Page 1 of 2





America

CERTIFICATE

No. U8 18 01 80346 018

Model(s):

S40#, S40z, S40#FT0, S40#SL4xy, S40#SL4xyz, S40#SR4xy, S40#SR4xyz

represents the mechanical option, described with up to 21 combinations of numbers and/or letters (0-9 and A-Z)

x represents the solenoid type, represented by 0, 1, 6 or 7

y represents the switching type, represented by 1 or 6

z represents the option Pod described with up to 18 combinations of numbers and/or letters (0-9 and A-Z)

The differences have no safety relevance.

Brand Name:

Fortress Interlocks

Parameters:

Models: S40#SL4xyz / S40#SR4xyz
 Rated Voltage: 24 Vdc
 Rated Current: 0.5 A

Models: S40z
 Rated Voltage: 24 Vac or 24 Vdc
 Rated Frequency: 50/60 Hz or dc
 Rated Current: 0.1 A

Models: S40#SL4xyz / S40#SR4xyz
 Rated Voltage: 24 Vdc (for xy Output)
 24 Vac or dc (for z Output)
 Rated Current: 0.5 A (for xy Output)
 0.1 A (for z Output)
 Rated Frequency: dc (for xy Output)
 50/60 Hz or dc (for z Output)

Models: Foot Adaptor
 Rated Voltage: No electrical Ratings

For all devices
 NEMA: Enclosure Type 1 (UL 50)

Tested according to:

UL 508:1999/R:2013-10
 CAN/CSA-C22.2 No. 14:2013-03

Production Facility(ies):

80346

Page 2 of 2